


Project: GripplE Hangers
Client: GripplE Ltd
Client's Order No: 3061
Inspection Date:
First: 25/03/2009

Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 25/03/2009

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
Surveyor of Lloyd's Register

WITNESSED / REVIEWED
Lloyd's Register
EMSA
Coventry Office
4/8/09


GripplE Model	Rope Construction	GripplE Rated Load	GripplE Load Limit 5:1	Result		
No 1 Y Fit M6 Stud	7 x 7 (6/1) Galvanised	0-10 kg 0-22 lbs	50 kg 100 lbs	105.6 kg 232.4 lbs	102.9 kg 226.3 lbs	99.1 kg 218.0 lbs
No 3 Y Fit M6 Stud	7 x 7 (6/1) Stainless Steel	45-90 kg 100-198 lb	450 kg 990 lbs	454.6 kg 1000.1 lbs	457.9 kg 1007.3 lbs	482.5 kg 1061.5 lbs

Project: GripplE Hangers
Client: GripplE Ltd
Client's Order No: 8624
Inspection Date:
First: 19/12/2007

Certificate No: COV 0719796
Office: Sheffield
Date: 21/01/2008
Order Status: Complete
Final: 21/01/2008

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
Surveyor of Lloyd's Register



GripplE Model	Rope Construction	GripplE Rated Load	GripplE Load Limit 5:1	Result		
No.2 Y-Fit M6 Stud	7x7 (6/1)	10 – 45 kg	225kg	284.8 kg	292.9 kg	269.0 kg
		22 – 100 lbs	500 lbs	626.6 lbs	644.4 lbs	591.8 lbs
No.3 Y-Fit M6 Stud	7x7 (6/1)	45 – 90 kg	450 kg	564.1 kg	577.3 kg	544.1 kg
		100 – 200 lbs	990 lbs	1241.0 lbs	1270.1 lbs	1197.0 lbs