

Project: Grippler Hangers

Client: Grippler Ltd

Client's Order No: 3061

Inspection Date:

First: 06/04/09

Certificate No: COV 0919097

Office: Sheffield


Date: 20/02/2009

Order Status: Complete


Final: 06/04/09

This certificate is issued to Grippler Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
Surveyor of Lloyd's Register



4/8/09

| Grippler Model | Rope Construction | Grippler Rated Load | Grippler Load Limit 5:1 | Result | | |
|---------------------|-------------------|---------------------|-------------------------|-----------------------|------------------------|---------------------|
| 1mm Y-fit snap-hook | 7 x 7 (6/ 1) | 0-10 Kg 0-22 lbs | 50 Kg 110 lbs | 99.9 Kg 219.78 lbs | 100.3 Kg 220.66 lbs | 100.0 Kg 220 lbs |


Grippler Ltd The Old West Gun Works Savile Street East Sheffield S4 7UQ
Tel: +44 (0)114 275 2255 Fax: +44 (0)114 275 1155
www.grippler.com email: info@grippler.com

Project: Grippler Hangers
Client: Grippler Ltd
Client's Order No: 3061
Inspection Date:
First: 25/03/2009


Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 25/03/2009

This certificate is issued to Grippler Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
Surveyor of Lloyd's Register




| Grippler Model | Rope Construction | Grippler Rated Load | Grippler Load Limit 5:1 | Result | | |
|----------------------|-------------------|------------------------|-------------------------|----------------------|----------------------|----------------------|
| No 2 Snap-Hook Y Fit | 7 x 7 (6/1) | 10-45 kg 22-100 lbs | 225 kg 495 lbs | 307.3 kg 676.0 lb | 279.4 kg 614.8 lb | 312.1 kg 686.6 lb |

Project: GripplE Hangers
Client: GripplE Ltd
Client's Order No: 8624
Inspection Date:
First: 19/12/2007


Certificate No: COV 0719796
Office: Sheffield
Date: 19/01/2008
Order Status: Complete
Final: 21/01/2008

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
Surveyor of Lloyd's Register



| GripplE Model | Rope Construction | GripplE Rated Load | GripplE Load Limit 5:1 | Result | | |
|----------------------|-------------------|-----------------------------|------------------------|------------------------|------------------------|------------------------|
| No.1 Y-Fit Snap Hook | 7x7 (6/1) | 0 -10 kg 0 - 22 lbs | 50kg 110 lbs | 78.1 kg 171.8 lbs | 81.6 kg 179.5 lbs | 68.3 kg 150.3 lbs |
| No.3 Y-Fit Snap Hook | 7x7 (6/1) | 45 - 90 kg 100 - 200 lbs | 450 kg 990 lbs | 599.4 kg 1318.7 lbs | 609.4 kg 1340.7 lbs | 585.0 kg 1287.0 lbs |